



Power Telematics ModPro Readings DynGen TG Series

Alarms		
Generator On/Running	Common Warning	Low Oil Pressure Warn
Extended Run 90min/4/8/12/24+ hours	Battery Voltage High	Overspeed Alarm
Not In Auto	Battery Voltage Low	Over Crank Alarm
Not in Auto 4+ hours	Low Fuel 50/25/10 %	High Fuel Level Alarm
Low Fuel Pressure	E Stop Active	Low Coolant Level
Battery Charger Fault	Battery Voltage Normal	Rupture Basin Alarm
Gen Supplying Load	High Engine Temp Alarm	Remote Start Active
Utility Supplying Load	High Engine Temp Warn	Low Fuel Alarm
Common Fault	Low Engine Temp Alarm	Running in Manual
Common Shutdown	Low Oil Pressure Alarm	Load Imbalance

Analog Values		
Oil Temp	Fuel Level	Gen Current L1
Coolant Temp	Gen Volts L1-L2	Gen Current L2
Oil Pressure	Gen Volts L2-L3	Gen Current L3
Battery VDC	Gen Volts L3-L1	DEF Level
RPM	Gen Frequency	Engine Hours