



Power Telematics ModPro Readings

Kohler DEC 340

Alarms		
Generator On/Running	Common Shutdown	Overspeed Alarm
Extended Run Alarms 90min/4/8/12/24+ hours	Battery Voltage High	Over Crank Alarm
Not In Auto	Battery Voltage Low	E Stop Active
Not in Auto 4+ hours	High Engine Temp Alarm	High Fuel Level Alarm
Battery Charger Fail	High Engine Temp Warn	Low Fuel Level Alarm
Gen Supplying Load	Low Engine Temp Alarm	Low Coolant Level
Utility Supplying Load	Low Oil Pressure Alarm	System Ready
Common Fault	Low Oil Pressure Warn	Battery Voltage Normal

Logging Values		
Coolant Temp	Gen Current L3	Gen Voltage L3-N
Oil Pressure	Gen Volts L1-L2	Gen Frequency
Battery VDC	Gen Volts L2-L3	Gen Total KW
RPM	Gen Volts L3-L1	Gen Total PF
Gen Current L1	Gen Voltage L1-N	Engine Hours
Gen Current L2	Gen Voltage L2-N	

*All value availability is determined by individual Controller Programming and Options.