



Power Telematics ModPro Readings

Kohler DEC550

Alarms		
Generator On/Running	Common Shutdown	Low Oil Pressure Alarm
Extended Run 90min/4/8/12/24+ hours	Common Warning	Low Oil Pressure Warn
Not In Auto	Battery Voltage High	Overspeed Alarm
Not in Auto 4+ hours	Battery Voltage Low	Over Crank Alarm
Battery Charger Fail	High Engine Temp Alarm	E Stop Active
Gen Supplying Load	High Engine Temp Warn	Low Fuel Level Alarm
Utility Supplying Load	Low Engine Temp Alarm	Low Coolant Level
Common Fault		

Logging Values		
Oil Temp	Gen Current L2	Gen Total KW
Coolant Temp	Gen Current L3	Gen Total PF
Oil Pressure	Gen Volts L1-L2	Gen Voltage L1-N
Battery VDC	Gen Volts L2-L3	Gen Voltage L2-N
RPM	Gen Volts L3-L1	Gen Voltage L3-N
Gen Current L1	Gen Frequency	Engine Hours